



P.O. Box 176
105 North Pecan
Roxton, Texas 75477

903-346-3535
Fax: 903-346-3759
Email: cityofroxton@yahoo.com

The Texas Commission on Environmental Quality(TECQ) has notified the City of Roxton TX1390014 that the drinking water being supplied to customer has exceeded the Maximum Contaminant Level (MCL) for haloacetic acid (group of five). The U.S. Environmental Protection Agency(U.S. EPA) has established the MCL for haloacetic acids (groups of five) to be 0.060 milligrams per liter (mg/L) Based on locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for haloacetic acids (group of five) indicates a compliance value in quarter three 2026 of 0.063 mg/L fir DBP2-02 and 0.064 mg/L for DBP2-01.

Haloacetic acids are group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally occurring organic matter in the water.

Some people who drink water containing HAA5 in excess of the MCL, over many years may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following action to address this issues: by flushing the lines.

Please share this information with people who may drink this water, especially Those who may not have received this notice directly(i.e., people in apartment, nursing home, school, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any question regarding this mater, you may contact City of Roxton Water Dept at 903-346-3535.

Posted/delivered on *August 18, 2026*